

Declaration of performance

№ 080/2016

According to Construction Products Regulation EU № 305/2011

1. *Unique identification code of the product-type:*

Conventional Fire Alarm System

2. *Type Number:*

List of components- Annex1

Description: The below mentioned products are designed, developed and manufactured in Teletek Electronics JSC

3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer*

Fire detection and fire alarm systems installed in and around buildings

4. *Manufacturer*

**Teletek Electronics JSC
14A Srebarna Str.
1407 Sofia, Bulgaria**

5. *Trading Company*

**Teletek Electronics JSC
14A Srebarna Str.
1407 Sofia, Bulgaria**

6. *System of assessment*

System 4

7. *Notified Body*

**SGS Bulgaria EOOD Ltd
BC MEGAPARK office "C", fl.6
115G bul. 'Tsarigradsko shose',
1784 Sofia, Bulgaria**

Notified Body Number

2 OCC

EC Certificate Number

BG13/88554.01

8. *No European Technical Assessment has been issued for this product.*

9. *Declared performance*

EN54-13:2005 Fire detection and fire alarm systems – Compatibility assessment of system components		
Clause	Description	Performance
4.2	Basic system requirements	Pass
4.3	Networked systems	Pass
4.4	Components	Pass
4.5	Transmission paths	Pass
4.6	Input and output devices linked to a fire protection system	Pass
5.2.1	Standard Atmospheric conditions for Tests	Pass
5.2.2	Mounting and electrical connection	Pass
5.3.3	Fire alarm condition	Pass
5.3.4	Fault warning condition	Pass
5.3.4.1	Open circuit on a transmission path	Pass
5.3.4.2	Short circuit on a transmission path	Pass
5.3.4.3	Interruption of mains power supply	Pass
5.3.5	Disablement condition	Pass
5.3.6	Test condition	Pass
5.4.3	Test for connectability	Pass
5.5	Electromagnetic compatibility test	Pass

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

1407 Sofia,
14A, Srebarna Str.
23.11.2016

Yuliy Iliev

Quality Manager



Annex1: System Components

Product name	Description	Certificate	Type
MAG4P, MAG4, MAG2P, MAG2	Conventional fire alarm control panel	1293-CPR-0510	1
MAG8	Conventional fire alarm control panel	1293-CPD-0373	1
MAG4Plus, MAG8Plus	Conventional fire alarm control panel	1293-CPD-0172	1
SensoMAG MCP50	Conventional call point	1293-CPD-0161	1
SensoMAG MCP50 IP67	Conventional call point	1293-CPR-0539	1
SensoMAG F10	Conventional fire detector	1293-CDP-0117	1
SensoMAG M40	Conventional fire detector	1293-CPR-0120	1
SensoMAG R20	Conventional fire detector	1293-CPR-0118	1
SensoMAG S30	Conventional fire detector	1293-CPR-0119	1

Annex2: Test Documentation

Accredited Laboratory	Report Number	Date
EVPU a.s. (SNAS testing S-042 and certification P-012)	00217B/1/2016	13.05.2016
	90013/2013	05.06.2013
	90016/2007	05.11.2007
	90003/2010	02.02.2010
	00029/2017/C	08.02.2017
	900209	17.03.2009
	23/2008N	10.12.2008
	90012/2009	09.02.2009
	22/2008N	11.12.2008