

DECLARATION OF CONFORMITY

We, **Teletek Electronics JSC**
Address: 2, Iliyansko shose Str.
1220 Sofia, Bulgaria

Declares that the

Product: **Duct Detector**

Description: Duct Detector Housing

Duct detector is compatible with:

Addressable fire alarm detectors SensoIRIS S130 IS.

Conventional fire alarm detectors SensoMAG S30.

Complies to the following standards:

EN 54-27:2015

The following Regulation:

REACH No 1907/2006

And the following Directives:

2011/65/EU- RoHS II

Additional information:

First date of production: 03.2025

2, Iliyansko shose Str.
1220 Sofia, Bulgaria
14.08.2025

Alek Artinyan
Quality Manager

